

**BUILDING AND STANDARDS COMMISSION  
STAFF REPORT**

**July 25, 2011**



**Case #1734 – 1008 Hall Street**



**LEGAL DESCRIPTION:** Lot 17 in Block 4 of Bryan's 3<sup>rd</sup> Subdivision

**STRUCTURE(S):**

- single-family residence
- multi-family residence
- mixed use
- commercial
- accessory structure(s)

**PROPERTY OWNER(S):** Espanola P Lewis

**LIENHOLDER(S)/  
MORTGAGEE(S):**

none

**IMPROVEMENT VALUE(S)  
(AS APPRAISED BY THE  
BRAZOS COUNTY**

**APPRAISAL DISTRICT):** \$23,090 (2011 tax year)

**BACKGROUND:** This property owner was contacted back in April, 2011 about the condition of the property after the Bryan Police Department referred it to Code Enforcement. The property owner was informed of the condition of the property and that it needed to be secured, repair permits obtained or demolished. At this time, the property is still unsecured.

**ATTACHMENTS:**

- (1.) staff recommendation
- (2.) pictures
- (3.) dangerous structures survey reports with recommendations

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**July 25, 2011**

**Case #: 1734**

**Building Address: 1008 Hall Street**

**Record Owner(s): Espanola P Lewis**

The City's Chief Building Official has requested this Commission hearing to discuss the building  and 1 accessory structure(s) on the same property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building  and/or accessory structure(s) they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired** so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired** in compliance with City ordinances.

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building  and accessory structure(s) from unauthorized entry within 30 days.
- demolish/remove** or  **repair** the building  and accessory structure(s) within 30 days.
- demolish/remove** or  **repair** the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building  and accessory structure(s) and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**

**PICTURES:**









CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1734

**A. PROPERTY DESCRIPTION**

Address 1008 Hall

Lot(s) 17 Block(s) 4 Addition(s) Bryan's 3rd

Owner(s) Espanola P Lewis, Teresa Tyson, Amita Petty, Juanita Petty, Bennie Petty, Patricia Gillimu, & Any other heirs of Odessa Petty

Mailing Address 2306 NW 49<sup>th</sup> Street, Lawton, OK 73505-1663

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories 1

Structures 2

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** Code violation observed - grass hasn't been mowed  
Structures interior has numerous personal belongings. There is also  
a small metal Morgan building in the back of the lot, which is not  
secured and also has personal items stored in it.

*Sandra Willis*  
Signature

Sandra Willis/Code Enforcement  
Printed Name/Title Officer

6/28/11  
Date

Case # 1734



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Chief Building Official

Case #1734

**A. PROPERTY DESCRIPTION**

Address 1008 Hall

Lot(s) 17 Block(s) 4 Addition(s) Bryan's 3rd

Owner(s) Espanola P Lewis, Teresa Tyson, Amita Petty, Juanita Petty, Bennie Petty, Patricia Gillimu, & Any other heirs of Odessa Petty

Mailing Address 2306 NW 49<sup>th</sup> Street, Lawton, OK 73505-1663

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories \_\_\_\_\_ Structures \_\_\_\_\_

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2009 IBC UNSAFE STRUCTURES
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.

- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.
- 07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
  - light
  - ventilation
  - sanitation facilities
- 08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
- 09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
  - Holes or cracks in the floor, exterior wall or roof
  - Loose, rotten, warped or protruding boards
- 10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
  - Defective materials
  - Structural deterioration
  - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS POUCH NOT ADEQUATELY SUPPORTED, IN DANGER OF COLLAPSE. UNSECURED.

---



---



---



---



---



---

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
  - A.  Be vacated OR  remain unoccupied; and
  - B. ~~Be repaired~~ OR  be demolished.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

Signature

Printed Name

Date

Case # \_\_\_\_\_



# Dangerous Structures Survey Report

Fire Marshal

Case #1734

A. PROPERTY DESCRIPTION

Address 1008 Hall

Lot(s) 17 Block(s) 4 Addition(s) Bryan's 3rd

Owner(s) Espanola P Lewis, Teresa Tyson, Amita Petty, Juanita Petty, Bennie Petty, Patricia Gillimu, & Any other heirs of Odessa Petty

Mailing Address 2306 NW 49<sup>th</sup> Street, Lawton, OK 73505-1663

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

STRUCTURAL USE

- Residential/Single Family  
 Mixed Use  
 Commercial  
 Residential/Multi Family  
 Accessory Structure

CONSTRUCTION

- Box  
 Frame  
 Masonry  
 Mobile Home

OCCUPANCY

- Occupied  
 Vacant  
 Open

C. FINDINGS

01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 22% of the structure is considered a loss.
02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.



*F. Taylor*

Signature

FROD Taylor / Deputy Fire Marshal

Printed Name/Title

Date 7-6-11

Case # \_\_\_\_\_