

**BUILDING AND STANDARDS COMMISSION
STAFF REPORT**

August 22, 2011



Case #1753 – 3008 First Street #A



LEGAL DESCRIPTION: Dellwood Park, Block 4, Lot pt of tract adj Lot 6

STRUCTURE(S):

- single-family residence
- multi-family residence
- mixed use
- commercial
- accessory structure(s)

PROPERTY OWNER(S): Pamela Sue Bateman, c/o Amber S. Cocke & Russell Bateman

LIENHOLDER(S)/

MORTGAGEE(S): n/a

IMPROVEMENT VALUE(S)

(AS APPRAISED BY THE

BRAZOS COUNTY

APPRAISAL DISTRICT): \$5,160 (2011 tax year)

BACKGROUND:

This mobile home was brought to the attention of Building Services when an individual was attempting to purchase this property and an inspection was made of the site.

ATTACHMENTS:

- (1.) staff recommendation
- (2.) pictures
- (3.) dangerous structures survey reports with recommendations

**BUILDING AND STANDARDS COMMISSION
STAFF RECOMMENDATION**



August 22, 2011

Case #: 1753

Building Address: 3008 First Street #A

Record Owner(s): Pamela Bateman, c/o Amber Cocke and Russell Bateman

The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):

- 1) The building, structure, or any part thereof is likely to partially or fully collapse.
- 2) The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3) One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4) The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5) The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6) The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7) The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8) The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9) The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

The City further recommends that the Commission find that:

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired** so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired** in compliance with City ordinances.

The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:

- vacate the building within ____ days.
- secure the building and accessory structure(s) from unauthorized entry within 30 days.
- demolish/remove the building within 30 days.**
- demolish/remove** or **repair** the building and accessory structure(s) within ____ days, in accordance with the schedule below:

Deadline

Task

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.

PICTURES:







CITY OF BRYAN
The Good Life, Texas Style.

Dangerous Structures Survey Report

Chief Building Official

Case # 1753

A. PROPERTY DESCRIPTION

Address 3008 First Street #A

Lot(s) Pt of tract adjacent to lot 6 Block(s) 4 Addition(s) Dellwood Park

Owner(s) Pamela Sue Bateman %Amber S Cocke & Russell H Bateman

Mailing Address 3609 Nevad Drive, San Angelo, TX 76904-7139

B. SPECIFICATIONS

Sq. Ft. _____ Rooms _____ Stories 1 Structures 1

STRUCTURAL USE

CONSTRUCTION

OCCUPANCY

- 1 Residential/Single Family
- _____ Mixed Use
- _____ Commercial
- _____ Residential/Multi Family
- _____ Accessory Structure

- _____ Box
- _____ Frame
- _____ Masonry
- 1 Mobile Home

- _____ Occupied
- 1 Vacant
- _____ Open

C. FINDINGS

X 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2009 IRC, 2005 NEC

_____ 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.

X 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.

X 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.


X 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.

- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.
- 07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
 - light
 - ventilation
 - sanitation facilities
- 08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
- 09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
 - Holes or cracks in the floor, exterior wall or roof
 - Loose, rotten, warped or protruding boards
- 10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
 - Defective materials
 - Structural deterioration
 - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS Home is located in flood way, back portion of structure overhanging creek with soil eroding away around rear supports, back portion of home has deflection in frame and water heater closet is overhanging creek and is not accessible. Toilet falling through floor in master bath (over creek). Home has mildew or mold inside. Rotten electrical service and meter pole.

D. DETERMINATION

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
 - A. Be vacated OR remain unoccupied; and
 - B. Be repaired OR be demolished.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.


Signature

GREGORY S. COX
Printed Name

7-7-11
Date



CITY OF BRYAN
The Good Life, Texas Style.

Dangerous Structures Survey Report

Fire Marshal

Case # 1753

A. PROPERTY DESCRIPTION

Address 3008 First Street #A

Lot(s) Pt of tract adjacent to lot 6 Block(s) 4 Addition(s) Dellwood Park

Owner(s) Pamela Sue Bateman %Amber S Cocke & Russell H Bateman

Mailing Address 3609 Nevad Drive, San Angelo, TX 76904-7139

B. SPECIFICATIONS

Sq. Ft. _____

Rooms _____

Stories 1

Structures 1

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 50% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. Be vacated OR remain unoccupied; and

B. Be repaired OR be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS The rear of the structure hangs over a ditch.

There is evidence of walls + roof deterioration due to roof leakage

[Signature]

FRED TAYLOR DSM

7-14-11



CITY OF BRYAN
The Good Life, Texas Style.

Dangerous Structures Survey Report

Code Enforcement

Case # 1753

A. PROPERTY DESCRIPTION

Address 3008 First Street #A

Lot(s) Pt of tract adjacent to lot 6 Block(s) 4 Addition(s) Dellwood Park

Owner(s) Pamela Sue Bateman %Amber S Cocke & Russell H Bateman

Mailing Address 3609 Nevad Drive, San Angelo, TX 76904-7139

B. SPECIFICATIONS

Sq. Ft. _____

Rooms _____

Stories _____

Structures _____

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

- ___ 01. The building, structure, or a part thereof is unsecured and open.
- ___ 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- ___ 03. The building, structure, or a part thereof presents an attractive nuisance to children.

D. DETERMINATION

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- ___ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

