

**BUILDING AND STANDARDS COMMISSION  
STAFF REPORT**

November 28, 2011



**Park Place Mobile Home Park – 2303 Bomber Drive  
Case #1774, #1782, #1783, #1784, #1785, #1786, #1787, #1788, and #1803)**



**LEGAL DESCRIPTION:** Lot 11 in Block 3 of Lakeview North Subdivision (1.26 acres)

**STRUCTURE(S):**

- single-family residence
- multi-family residence
- mixed use
- commercial
- accessory structure(s)

**PROPERTY OWNER(S):** Jason Millsap (#s 2, 5, 6, 9, 11, 12, 13, 14) and Lenard Millsap (#16) – the property on which these manufactured homes is located is owned by Jason Millsap

**LIENHOLDER(S)/  
MORTGAGEE(S):** none

**IMPROVEMENT VALUE(S) AND MANUFACTURED DATES FROM BRAZOS COUNTY APPRAISAL DISTRICT FOR 2011 TAX YEAR:**

CASE #1774 (LOT 2): \$2,200 (1983)

CASE #1782 (LOT 5): \$1,380 (1969)

CASE #1783 (LOT 6): \$1,840 (1971)

CASE #1784 (LOT 9): \$1,610 (1971)

CASE #1785 (LOT 11): \$750 (1971)

CASE #1786 (LOT 12): \$2,000 (unknown date)

CASE #1787 (LOT 13): \$1,730 (1970)

CASE #1788 (LOT 14): \$1,730 (1972)

CASE #1803 (LOT 16): \$1,350 (1969)

**BACKGROUND:**

Since March 2009, City staff has been in discussions with park owner Jason Millsap concerning general violations at his park, City Council's mandate to enforce the manufactured housing park ordinance and the removal of unsafe/damaged homes from his park. More than 2 years later several damaged, unoccupied manufactured homes have remained in the park. All of them are unsecured and allow unauthorized entry.

**ATTACHMENTS FOR EACH CASE:**

- (1.) staff recommendation
- (2.) pictures
- (3.) dangerous structures survey reports with recommendations

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1774**

**Building Address: 2303 Bomber Drive, Lot # 2**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 2**



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Chief Building Official

Case # 1774

A. PROPERTY DESCRIPTION

Address 2303 Bomber #2

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2005 NEC, 2009 IRC, STATE LAW ON ANCHORS & TIE DOWNS

- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.

- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.

- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.

- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.


- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
- light
  - ventilation
  - sanitation facilities
08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
- Holes or cracks in the floor, exterior wall or roof
  - Loose, rotten, warped or protruding boards
10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
- Defective materials
  - Structural deterioration
  - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) DEBRIS ON PORCH (2) PORCH / STEPS NEED REPAIRS  
 1/2 NEEDS HANDRAIL (3) DAMAGED ELECTRICAL DEVICES  
 (4) DAMAGED LANDING (5) DAMAGED OR MISSING SKIRTING  
 (6) DEBRIS ON INSIDE (7) LOOSE ELECTRICAL BOX  
 (8) ROTTEN STRUCTURAL SILL (9) HOLES IN FLOOR  
 (10) ROTTEN FLOORS THROUGHOUT (11) ROTTEN WALL AT  
 LIVING ROOM WALL (WALL IS LOOSE) (12) NO STATE TAGS

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
- A.  Be vacated OR  remain unoccupied; and
  - B.  Be repaired OR  be demolished.
2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

  
 Signature

GREGORY S. COX  
 Printed Name

10-15-11  
 Date



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1774

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #2

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** Windows are unlocked - unsecured and there is debris on the front porch. Broken glass on windows.

The debris includes a desk, siding, skirting material. Interior has boxes and scattered clothes and personal belongings everywhere.

No visible HUD plates.

*Sandra Willis*

Signature

Sandra Willis / Code Officer

Printed Name/Title

10-12-11

Date

Case # 1774



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Fire Marshal

Case # 1774

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #2

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories 1

Structures 7

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

X 06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

X 07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

X 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR X remain unoccupied; and

B. \_\_\_ Be repaired OR X be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. Gae receptacles pulled from wall

2 open exterior receptacles

3 rotten walls

4 open wires

5 unsecured

6 rotten floor sills

7 open cracks in ceiling

Fred Taylor Fred Taylor DSW 2017-11

---

Signature

Printed Name/Title

Date

Case # \_\_\_\_\_

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1782**

**Building Address: 2303 Bomber Drive, Lot # 5**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 5**



# Dangerous Structures Survey Report

Chief Building Official

Case # 1782

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #5

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2009 IRC, 2005 NEC
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
- light
  - ventilation
  - sanitation facilities
08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
- Holes or cracks in the floor, exterior wall or roof
  - Loose, rotten, warped or protruding boards
10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
- Defective materials
  - Structural deterioration
  - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS ① WATER HEATER FALLING THROUGH FLOOR ② ROTTEN DOORS ③ ROTTEN WALLS AROUND WINDOWS (WALL LOOSE ④ ROTTEN FLOORS ⑤ DAMAGED OR MISSING SKIRTING ⑥ STEPS/LANDINGS/HANDRAILS MISSING OR DO NOT MEET CODE

PARK DOES NOT HAVE LICENSE TO OPERATE

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
- A.  Be vacated OR  remain unoccupied; and
  - B.  Be repaired OR  be demolished.
2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

Gregory Slop  
Signature

GREGORY S COX  
Printed Name

10-15-11  
Date



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1782

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #5

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** Back door was open/unsecured. No electric meter  
No visible HUD plate.

*Sandra Willis*  
Signature

Sandra Willis / Cook Officer  
Printed Name/Title

10-12-11  
Date



# Dangerous Structures Survey Report

Fire Marshal

Case # 1782

## A. PROPERTY DESCRIPTION

Address 2303 Bomber #5

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

## B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories 1

Structures 1

### STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

### CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

### OCCUPANCY

- Occupied
- Vacant
- Open

## C. FINDINGS

01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR  remain unoccupied; and

B. \_\_\_ Be repaired OR  be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. unsecured

2 floor not level

3 Roof leaks

4 Bath Room floor rotten

5 TVB Surround ROTTEN

6 Elec panel 13 fuses

7. Elec recepticles pulled from wall

*[Signature]*

FRED TAYLOR DEM

10-17-11

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1783**

**Building Address: 2303 Bomber Drive, Lot # 6**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 6**



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Chief Building Official

Case # 1783

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #6

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2005 NEC, 2009 IRC
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.

09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:

- Holes or cracks in the floor, exterior wall or roof
- Loose, rotten, warped or protruding boards

10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:

- Defective materials
- Structural deterioration
- Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) HOLES IN ROOF / ROOF LEAKS (2) LOOSE ANCHORS (3) LEAKY ROOF (4) ROTTEN FLOORS (5) ELEC PLUG COVERS MISSING

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

- A.  Be vacated OR  remain unoccupied; and
- B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

Gregory S Cox  
Signature

GREGORY S COX  
Printed Name

10-15-11  
Date



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1783

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #6

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** Unlocked back door, no electric meter  
No visible HUD plate

*Sandra Willis*  
Signature

Sandra Willis/Code Officer  
Printed Name/Title

10-12-11  
Date

Case # 1783



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Fire Marshal

Case # 1783

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #6

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

   07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

   1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.    Be vacated OR    remain unoccupied; and

B.    Be repaired OR    be demolished.

   2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

- 1. Rotten Floor Beams
- 2 open wiring
- 3 BAD WALLS
- 4 BAD FLOORS
- 5 Leaking Ceiling
- 6. Holes in exterior walls

      Fred Taylor DFM 10-17-11

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1784**

**Building Address: 2303 Bomber Drive, Lot # 9**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 9**



# Dangerous Structures Survey Report

Chief Building Official

Case # 1784

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #9

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2005 NEC, 2009 IRC, STATE LAW ON ANCHORS/TIE DOWN

02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.

03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.

04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.

05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.


06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
- light
  - ventilation
  - sanitation facilities
08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
- Holes or cracks in the floor, exterior wall or roof
  - Loose, rotten, warped or protruding boards
10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
- Defective materials
  - Structural deterioration
  - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) ROT ALL AROUND DOOR AT FRAME, DOOR NOT ORIGINAL  
 (2) ROTTEN WATER HEATER FLOOR (3) ROTTEN/LOOSE  
 WALLS AROUND WINDOWS (4) ROTTEN FLOORS (5)  
 ROOF SAGGING. (6) CEILING FINISHES SAGGING/FALLING  
 (7) LOOSE/MISSING TIE DOWN ANCHORS (8) DAMAGED  
 OR MISSING SKIRTING

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
- A.  Be vacated OR  remain unoccupied; and
  - B.  Be repaired OR  be demolished.
2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

  
 Signature

GREGORY S. COX  
 Printed Name

10-15-11  
 Date



# Dangerous Structures Survey Report

Code Enforcement

Case # 1784

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #9

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** OSB flooring pieces and lumber under the mobile home. Interior of mobile home has fuse box with eight fuses ~~fuses~~ in the panel box.

No visible HUD plates.

*Sandra Willis*  
Signature

Sandra Willis / Code Officer  
Printed Name/Title

10.12.11  
Date



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Fire Marshal

Case # 1784

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #9

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR  remain unoccupied; and

B. \_\_\_ Be repaired OR  be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. wiring problems  
2 rotter ceiling, walls, floors  
3 mold/mildew

*[Signature]* FRED TAYLOR DSM 10-17-11

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1785**

**Building Address: 2303 Bomber Drive, Lot # 11**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 11**



# Dangerous Structures Survey Report

Chief Building Official

Case # 1785

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #11

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2005 NEC, 2009 IRC, STATE LAW ON ANCHORS
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.

09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:

- Holes or cracks in the floor, exterior wall or roof
- Loose, rotten, warped or protruding boards

10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:

- Defective materials
- Structural deterioration
- Interior walls or ceilings with holes, cracks or loose plaster


COMMENTS (1) MISSING ANCHORS/STRAPS (2) ROTTEN WALLS AROUND WINDOWS - LOOSE WALLS (3) ALUMINUM WIRING (4) ROTTEN FLOORS (5) DAMAGED ELECTRICAL (6) STEPS/LANDINGS/HANDRAILS MISSING OR DO NOT MEET CODE (7) MISSING OR DAMAGED CRAWL SPACE SKIRTING

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

- A.  Be vacated OR  remain unoccupied; and
- B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

  
Signature

GREGORY S COX  
Printed Name

10-15-11  
Date

Case # \_\_\_\_\_



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1785

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #11

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.





CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Fire Marshal

Case # 1785

## A. PROPERTY DESCRIPTION

Address 2303 Bomber #11

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

## B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

### STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

### CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

### OCCUPANCY

- Occupied
- Vacant
- Open

## C. FINDINGS

01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 50% of the structure is considered a loss.
02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.  Be vacated OR  remain unoccupied; and

B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. unsecured

2. Burnout

3. Aluminum wire

*[Signature]* Fred Taylor JFM 10-17-11

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1786**

**Building Address: 2303 Bomber Drive, Lot # 12**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 12**



# Dangerous Structures Survey Report

Chief Building Official

Case # 1786

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #12

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2005 NEC, 2009 IRC
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.

09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:

- Holes or cracks in the floor, exterior wall or roof
- Loose, rotten, warped or protruding boards

10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:

- Defective materials
- Structural deterioration
- Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) LOOSE EXTERIOR LIGHT FIXTURE (2) ROTTEN WALL AT KITCHEN (3) CEILING SAGGING, POSSIBLE STRUCTURAL DAMAGE BEHIND FINISHES FROM ROOF LEAKS (4) ALUMINUM WIRING (5) STEPS, LANDINGS, HANDRAILS NOT CODE COMPLIANT. (6) DAMAGED OR MISSING SKIRTING


D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.  Be vacated OR  remain unoccupied; and

B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

  
Signature

GREGORY S. COX  
Printed Name

10-15-11  
Date

Case # \_\_\_\_\_



# Dangerous Structures Survey Report

Code Enforcement

Case # 1786

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #12

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** Tin-corrugated metal sheets were scattered on one side of the mobile home. Seems like skirting material. No HUD plate visible. Window in one of the bedrooms shattered and mattress found inside. No electric meter.

*Sandra Willis*  
Signature

Sandra Willis / Code Officer  
Printed Name/Title

10-12-11  
Date



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Fire Marshal

Case # 1786

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #12

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR  remain unoccupied; and

B. \_\_\_ Be repaired OR  be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. Floors Bax

2. Electrical Issues

3. Ceiling Leaks

*[Signature]* FRED TAYLOR JSM 10-17-11

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1787**

**Building Address: 2303 Bomber Drive, Lot # 13**

**Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 13**



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Chief Building Official

Case # 1787

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #13

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2005 NEC, 2009 IRC, STATE LAW ON ANCHORS

- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.

- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.

- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.

- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.

- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.

09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:

- Holes or cracks in the floor, exterior wall or roof
- Loose, rotten, warped or protruding boards

10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:

- Defective materials
- Structural deterioration
- Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) FIRE DAMAGE (2) MAJOR STRUCTURAL DAMAGE  
(3) WINDOWS MISSING GLASS (4) OPEN SEWER (5)  
DAMAGED DOORS (6) DAMAGED OR MISSING INTERIOR FINISHES  
(7) ALUMINUM WIRING (8) LOOSE ANCHORS & STRAPS  
(9) STEPS/LANDINGS/HANDRAILS MISSING OR DO NOT MEET CODE  
(10) DAMAGED OR MISSING SKIRTINGS  
PARK DOES NOT HAVE LICENSE TO OPERATE IN CITY

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

- A.  Be vacated OR  remain unoccupied; and
- B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

  
Signature

Gregory S Cox  
Printed Name

10-15-11  
Date

Case # \_\_\_\_\_



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1787

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #13

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories / Structures /

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** Broken windows, mobile home has fire damage and interior being used for storage of tires, commodes, mattresses. Back door secured with 2x4's across it. No visible HUD plate.

*Sandra Willis*  
Signature

Sandra Willis / Code Officer  
Printed Name/Title

10.12.11  
Date

Case # 1787



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Fire Marshal

Case # 1787

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #13

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories 1

Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 1 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- X 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 0 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- X 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- X 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR  remain unoccupied; and

B. \_\_\_ Be repaired OR  be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. unsecured  
2. Burn out  
3. AC wire

*[Signature]* Fred Toyne DFM 10-17-11

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1788,  
Building Address: 2303 Bomber Drive, Lot # 14  
Record Owner(s): Jason Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 14**



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Chief Building Official

Case # 1788

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #14

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2005 NBC, 2009 IRC
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.

09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:

- Holes or cracks in the floor, exterior wall or roof
- Loose, rotten, warped or protruding boards

10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:

- Defective materials
- Structural deterioration
- Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) ROTTEN / LOOSE WALLS (2) ALUMINUM WIRING (3)  
ROTTEN FLOOR IN BED ROOM (4) MISSING GLASS IN DOOR  
(5) ROTTEN FLOOR IN KITCHEN (6) ROTTEN FLOOR  
BY ENTRY DOOR. (7) MISSING SKIRTING (8)  
STEPS/HANDRAILS/LANDINGS DO NOT MEET CODE.

PARK IS NOT LICENSED TO OPERATE


D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.  Be vacated OR  remain unoccupied; and

B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

  
Signature

GREGORY S COX  
Printed Name

10-15-11  
Date

Case # \_\_\_\_\_



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1788

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #14

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories 1

Structures 1

**STRUCTURAL USE**

**CONSTRUCTION**

**OCCUPANCY**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** NO visible HUD tag. Front door un-secured, unlocked. Looks like electrical wiring was pulled out from interior wall.

*Sandra Willis*  
Signature

*Sandra Willis / Code Officer*  
Printed Name/Title

10-12-11  
Date

Case # \_\_\_\_\_



# Dangerous Structures Survey Report

Fire Marshal

Case # 1788

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #14

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Jason Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories 1

Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 20% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

X 06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

X 07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

X 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR ^ \_\_\_ remain unoccupied; and

B. \_\_\_ Be repaired OR X be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

1. Some one had been staying inside

2. All wire

3. BAD floors + walls

Juliana FRED TAYLOR 10-17-11 JFM

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**November 28, 2011**

**Case #: 1803**

**Building Address: 2303 Bomber Drive, Lot # 16**

**Record Owner(s): Lenard Millsap**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building from unauthorized entry within 30 days.**
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**



**2303 Bomber Drive, Lot # 16**



CITY OF BRYAN  
The Good Life, Texas Style™

# Dangerous Structures Survey Report

Chief Building Official

Case # 1803

## A. PROPERTY DESCRIPTION

Address 2303 Bomber #16

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Leonard Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

## B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

### STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

### CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

### OCCUPANCY

- Occupied
- Vacant
- Open

## C. FINDINGS

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2005 NEC, 2009 IRC, STATE LAW ON ANCHORS
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated. (LOOSE ANCHORS)
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.

09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:

- Holes or cracks in the floor, exterior wall or roof
- Loose, rotten, warped or protruding boards

10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:

- Defective materials
- Structural deterioration
- Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) OPEN SEWER LINE (2) NO CODE COMPLIANT STEPS, LANDINGS, OR HANDRAILS (3) NO SKIRTING (4) FULL OF CLOTHES & DEBRIS (5) LOOSE ELECTRICAL OUTLETS (6) BROKEN WINDOWS (7) DAMAGE/ROT TO BACK DOOR & FRAME (8) ROTTEN FLOORS (9) STEPS/LANDINGS/HANDRAILS DO NOT MEET CODE


PARK DOES NOT HAVE LICENSE TO OPERATE IN THE CITY

D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

- A.  Be vacated OR  remain unoccupied; and
- B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.



Signature

GREGORY S COX

Printed Name

10-15-11

Date

Case # \_\_\_\_\_



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1803

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #16

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Leonard Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

**COMMENTS** No visible HUD tag, door was secured, broken window, food in cabinets,  
clothes scattered, shoes, and personal belongings all over interior.

No HUD plates visible - Wood pieces scattered on front end of mobile home.

*Sandra Willis*

Signature

*Sandra Willis / Code Officer*

Printed Name/Title

*10.12.11*

Date

Case # 1803



# Dangerous Structures Survey Report

Fire Marshal

Case # 1803

**A. PROPERTY DESCRIPTION**

Address 2303 Bomber #16

Lot(s) 11 Block(s) 3 Addition(s) Lakeview North (Park Place MHP)

Owner(s) Leonard Millsap

Mailing Address 2004 Pinewood Drive, Bryan, Texas 77807

**B. SPECIFICATIONS**

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

**STRUCTURAL USE**

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

**CONSTRUCTION**

- Box
- Frame
- Masonry
- Mobile Home

**OCCUPANCY**

- Occupied
- Vacant
- Open

**C. FINDINGS**

- X 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- 1 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- X 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- X 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- X 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.

^ 06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

X 07. The structure or a part thereof is in violation of the City's fire code.

D. DETERMINATION

X 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. \_\_\_ Be vacated OR X remain unoccupied; and

B. \_\_\_ Be repaired OR X be demolished.

\_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

- 1. Open elec wiring
- 2. Rotten walls
- 3 unsecured
- 4 Rotten floor
- ~~5 open cracks in ceiling~~
- 5. someone staying inside

*[Signature]* Fred Taylor Dem 10-17-11

---

Signature

Printed Name/Title

Date

Case # \_\_\_\_\_