


**BUILDING AND STANDARDS COMMISSION  
STAFF REPORT**

**September 24, 2012**



**Case #1849 – 608 W. Martin Luther King Jr. Street**



**LEGAL DESCRIPTION:** Lot 1 in Block 201 of City of Bryan Townsite

**STRUCTURE(S):**

- single-family residence
- multi-family residence
- mixed use
- commercial
- accessory structure(s)

**PROPERTY OWNER(S):** Pamela R. Franklin

**LIENHOLDER(S)/  
MORTGAGEE(S):** none

**IMPROVEMENT VALUE(S)  
(AS APPRAISED BY THE  
BRAZOS COUNTY  
APPRAISAL DISTRICT):** \$7,890 (2012 tax year)

**BACKGROUND:**

This property was brought to our attention by the Fire Marshal and Building Services due to an elderly man residing in the accessory structure behind the primary residence. The property owner, Pamela R. Franklin, was asked to keep the structure unoccupied due to its dilapidated and inhabitable condition. She advised her stepfather would normally stay on the porch of this structure to keep an eye on the main house while she was out of town, because she had previously been victim of theft. On July 31, 2012 the structure was still occupied by Mr. Sammie Lee, Pamela Franklin's stepfather.

On August 30, 2012, Ms. Franklin called asking that a copy of a voluntary demolition affidavit to be mailed to her so she could return it to City staff prior to the Building and Standards Commission meeting.

**ATTACHMENTS:**

- (1.) staff recommendation
- (2.) pictures
- (3.) dangerous structures survey reports

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**September 24, 2012**

**Case #: 1849**

**Building Address: 608 W Martin Luther King Jr Street**

**Record Owner(s): Pamela R. Franklin**

**The City's Chief Building Official has requested this Commission hearing to discuss the accessory structure on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the accessory structure they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the accessory structure unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired** in compliance with City ordinances.

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building  and accessory structure(s) from unauthorized entry within 30 days.
- demolish/remove the accessory structure within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---




---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City further recommends that the Commission order the City to demolish the building and accessory structure(s) and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**

**PICTURES: 07-31-12**



Electrical hazards





Dead rodent on floor




Daylight coming through roof



Water /sewer lines in the middle of the floor



Cardboard used to patch walls





CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Chief Building Official

Case # 1849-SW

## A. PROPERTY DESCRIPTION

Address 608 West Martin Luther King Jr Street

Lot(s) 1 Block(s) 201 Addition(s) City of Bryan

Owner(s) Pamela R Franklin

Mailing Address 608 W MLK Jr Street, Bryan, TX 77803-2616

## B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

### STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

### CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

### OCCUPANCY

- Occupied
- Vacant
- Open

## C. FINDINGS

- 01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:  
2005 NEC 2009 IRC
- 02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.
- 03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.
- 04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.
- 05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.



- 06. The structure or any part thereof has inadequate means of egress as required by the city's building code.
- 07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
  - light
  - ventilation
  - sanitation facilities
- 08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
- 09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
  - Holes or cracks in the floor, exterior wall or roof
  - Loose, rotten, warped or protruding boards
- 10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
  - Defective materials
  - Structural deterioration
  - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) NO CEILING IN LIVING ROOM (CARD BOARD ON CEILING)  
 SOFT FLOODS IN LIVING ROOM (2) ROTTEN WAUS &  
 ROOF FRAMING (3) BED ROOM (CARD BOARD ON WAUS &  
 CEILING (4) EXTENSION CORDS (5) WAUS OUT  
 OF PLUMB (6) PORCH CEILING ROTTEN (7) ROOF DAMAGED  
 (8) NO BATH ROOM OR KITCHEN  
 ACCESSORY STORAGE BLDG BEHIND <sup>MAIN</sup> HOUSE

**D. DETERMINATION**

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
  - A.  Be vacated OR  remain unoccupied; and
  - B.  Be repaired OR  be demolished.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

NO GAS METER

*Gregory S. Cox*

Signature

GREGORY S. COX

Printed Name

7-31-12

Date



CITY OF BRYAN  
The Good Life, Texas Style.

# Dangerous Structures Survey Report

Code Enforcement

Case # 1849-SW

A. PROPERTY DESCRIPTION

Address 608 West Martin Luther King Jr Street

Lot(s) 1 Block(s) 201 Addition(s) City of Bryan

Owner(s) Pamela R Franklin

Mailing Address 608 W MLK Jr Street, Bryan, TX 77803-2616

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_

Rooms \_\_\_\_\_

Stories \_\_\_\_\_

Structures \_\_\_\_\_

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

D. DETERMINATION

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.





CITY OF BRYAN  
The Good Life, Texas Style

# Dangerous Structures Survey Report

Fire Marshal

Case # 1849-SW

A. PROPERTY DESCRIPTION

Address 608 West Martin Luther King Jr Street

Lot(s) 1 Block(s) 201 Addition(s) City of Bryan

Owner(s) Pamela R Franklin

Mailing Address 608 W MLK Jr Street, Bryan, TX 77803-2616

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories \_\_\_\_\_ Structures \_\_\_\_\_

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.
- 06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.  
D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.  Be vacated OR  remain unoccupied; and

B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS Building out of plumb

no power

no heat

holes in ceiling

holes in walls

holes in floor

no toilet facilities

 FRED TAYLOR DEM

7-31-12