

**BUILDING AND STANDARDS COMMISSION  
STAFF REPORT**

**July 22, 2013**



**Case #1957 – 1212 Clark Street**



**LEGAL DESCRIPTION:** Lots 3 and 4 in Block 30 of Castle Heights

**STRUCTURE(S):**

- single-family residence
- multi-family residence
- mixed use
- commercial
- accessory structure(s)

**PROPERTY OWNER(S):** A. J. Monroe and Evelyn Monroe

**LIENHOLDER(S)/  
MORTGAGEE(S):**

none

**IMPROVEMENT VALUE(S)  
(AS APPRAISED BY THE  
BRAZOS COUNTY  
APPRAISAL DISTRICT):**

\$25,750 (2013 tax year)

**BACKGROUND:**

Code Enforcement found the structure on this property unsecured in August 2011. Notice was sent to the owners to secure that structure and that the structure needed repairs. The property owner secured the structure and applied for a demolition permit a few months ago. The sewer to the structure has been capped and inspected, but as of July 5, 2013, no demolition work has started on the house.

**ATTACHMENTS:**

- (1.) staff recommendation
- (2.) pictures
- (3.) dangerous structures survey reports

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**July 22, 2013**

**Case #: 1957**

**Building Address: 1212 Clark Street**

**Record Owner(s): A. J. Monroe and Evelyn Monroe**

**The City's Chief Building Official has requested this Commission hearing to discuss the on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is occupied and poses a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the accessory structure(s) is/are occupied and pose a hazard to health, safety, or general welfare of the occupants and/or the general public and must be vacated.
- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.

- the accessory structure(s) is/are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structure(s).
- the building may feasibly be repaired so that it is no longer in violation of City ordinances.
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- vacate the building within \_\_\_\_ days.
- secure the building  and accessory structure(s) from unauthorized entry within 30 days.
- demolish/remove the building within 30 days.**
- demolish/remove or  repair the building  and accessory structure(s) within \_\_\_\_ days, in accordance with the schedule below:

Deadline

Task

---



---



---



---



---

- appear before the Commission at each regularly scheduled meeting to demonstrate compliance with the time schedule, until the preceding orders have been fulfilled.

**The City recommends that the Commission orders that the City may:**

- disconnect water and electric utilities to the building.**
- secure the structure, demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**

**PICTURES TAKEN 06/04/2013:**







# Dangerous Structures Survey Report

Chief Building Official

Case 1957 - SH

A. PROPERTY DESCRIPTION

Address: 1212 Clark Street

Lot(s) 3 & 4 Block(s) 30 Addition(s) Castle Heights

Owner(s) A J Monroe and wife Evelyn Monroe

Mailing Address: 8770 Mark, College Station Texas 77845

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_

Rooms 6

Stories 1

Structures 1

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2009 IRC / 2005 NEC

02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base.

03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated.

04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated.

05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.

06. The structure or any part thereof has inadequate means of egress as required by the city's building code.
07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:
- light
  - ventilation
  - sanitation facilities
08. Injury to persons or damage to property will result because portion, member or appurtenance is likely to fail, become detached or dislodged, or collapse.
09. Unable to give reasonable protection to any occupants from weather elements or danger of collapse because of:
- Holes or cracks in the floor, exterior wall or roof
  - Loose, rotten, warped or protruding boards
10. Is manifestly unsafe for the purpose for which it is being used or so as not to give reasonable protection from danger of collapse or fire because of:
- Defective materials
  - Structural deterioration
  - Interior walls or ceilings with holes, cracks or loose plaster

COMMENTS (1) DAMAGED SIDING (2) FOUNDATION DAMAGED/ROTTEN  
 SUPPORT BEAMS (3) TERMITE DAMAGE (4) PLUMBING  
 DAMAGE (5) ROOF LEAKS / SOME CEILING DAMAGE  
 (6) INTERIOR FINISHES DAMAGED (7) MISSING BLANKS  
 AT EJECT. PANEL (8) DAMAGED PLUMBING (9) NO  
 WATER HEATER (10) OPEN SEWER (11) HOLES  
 IN EXTERIOR WALLS


D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
- A.  Be vacated OR  remain unoccupied; and
  - B.  Be repaired OR  be demolished.
2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

*Gregory S. Cox*  
Signature

Gregory S. Cox  
Printed Name

6-10-13  
Date





CITY OF BRYAN  
The Good Life, Texas Style™

# Dangerous Structures Survey Report

Code Enforcement

Case #1957 - SH

A. PROPERTY DESCRIPTION

Address: 1212 Clark Street

Lot(s) 3 & 4 Block(s) 30 Addition(s) Castle Heights

Owner(s) A J Monroe and wife Evelyn Monroe

Mailing Address: 8770 Mark, College Station Texas 77845

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories \_\_\_\_\_ Structures \_\_\_\_\_

STRUCTURAL USE

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

CONSTRUCTION

- Box
- Frame
- Masonry
- Mobile Home

OCCUPANCY

- Occupied
- Vacant
- Open

C. FINDINGS

- 01. The building, structure, or a part thereof is unsecured and open.
- 02. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
- 03. The building, structure, or a part thereof presents an attractive nuisance to children.

D. DETERMINATION

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured or has been secured and must remain so.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.





# Dangerous Structures Survey Report

Fire Marshal

Case 1957 - SH

A. PROPERTY DESCRIPTION

Address: 1212 Clark Street

Lot(s) 3 & 4 Block(s) 30 Addition(s) Castle Heights

Owner(s) A J Monroe and wife Evelyn Monroe

Mailing Address: 8770 Mark, College Station Texas 77845

B. SPECIFICATIONS

Sq. Ft. \_\_\_\_\_ Rooms \_\_\_\_\_ Stories 1 Structures 1

STRUCTURAL USE

- Residential/Single Family  
 Mixed Use  
 Commercial  
 Residential/Multi Family  
 Accessory Structure

CONSTRUCTION

- Box  
 Frame  
 Masonry  
 Mobile Home

OCCUPANCY

- Occupied  
 Vacant  
 Open

C. FINDINGS

01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare. I estimate that 100% of the structure is considered a loss.
02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.
06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.

07. The structure or a part thereof is in violation of the City's fire code.  
D. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
- A. \_\_\_ Be vacated OR  remain unoccupied; and
  - B. \_\_\_ Be repaired OR  be demolished.
- \_\_\_ 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

COMMENTS

Plumbing removed  
Holes in walls  
Holes in floors  
open ceiling  
sewage / water leaks  
wiring removed

*[Signature]* Fred Taylor Deputy Fire Marshal 6-7-13