


**BUILDING AND STANDARDS COMMISSION  
STAFF REPORT**

**June 22, 2015**



**Case #2111 – 905 West 16<sup>th</sup> Street**



**LEGAL DESCRIPTION:** Sunset Ph.2, Block 2, Lot 5

**STRUCTURE(S):** single-family residence

**PROPERTY OWNER(S):** Thompson-Sumlin Lena M.

**LIENHOLDER(S)/  
MORTGAGEE(S):** none

**ACTIVE UTILITIES:**  yes  no **DISCONNECTED ON:** 10/09/2014

**BRAZOS COUNTY APPRAISAL DISTRICT/TAX OFFICE INFORMATION:**

**PROPERTY ID:** 44681  
**IMPROVEMENT VALUE:** \$18,370  
**YEAR BUILT:** 1940  
**SF OF LIVING AREA:** 828  
**CURRENT OWNER SINCE:** 2/22/2012  
**PROPERTY TAXES OWED:** \$868.25 (2013)  
\$1559.81 (2009-2011)

**BACKGROUND:**

- While meeting with an owner of a dilapidated house on a nearby lot in early 2015, City staff noticed this structure was vacant and dilapidated also.
- Notices that the property has an electrical hold on it from the Deputy Fire Marshal had been mailed to the property owner on February 6, 2015.
- Notices that the property would be scheduled for consideration by the Building and Standards Commission were mailed to the property owner on April 6, 2015 and May 18, 2015

**ATTACHMENTS:**

1. staff recommendation
2. pictures
3. dangerous structures survey reports

**BUILDING AND STANDARDS COMMISSION  
STAFF RECOMMENDATION**



**June 22, 2015**

**Case #: 2111**

**Building Address: 905 West 16<sup>th</sup> Street**

**Record Owner(s): Thompson-Sumlin Lena M.**

**The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):**

- 1)  The building, structure, or any part thereof is likely to partially or fully collapse.
- 2)  The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3)  One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4)  The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5)  The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6)  The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7)  The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8)  The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9)  The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

**The City further recommends that the Commission find that:**

- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**
  
- the building may not be feasibly repaired in compliance with City ordinances.**

**The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:**

- secure the building from unauthorized entry within 30 days.**
- demolish the building and remove the debris within 30 days.**

**The City recommends that the Commission orders that the City may:**

- disconnect water and electric utilities to the building.**
- secure the structure, demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**

**PICTURES:**



Front of house




Rotten siding and trim



Rotten siding, framing, damaged insulation  
Missing crawl space skirting



Trash and debris in yard



Rotten trim



Rear exterior



Means of egress not to code



Exposed/rotten foundation and wall framing



Side of house



Water damage on interior, rot



Sheetrock water damage, rot



Holes in walls, someone may be trying to steal copper wiring



More holes in interior walls



Ceiling finish removed, damaged light fixture



Exposed ceilings, wiring



Damaged interior walls and framing



Kitchen – hole in wall



Vent not properly set on gas water heater



Sheetrock damage from water leak, mold



Gap at foundation between slab and pier and beam,  
At rear room of house



Another room missing ceiling finish



# Dangerous Structures Survey Report

Chief Building Official

Case # 2111

A. PROPERTY ADDRESS: 905 W 16<sup>th</sup> Street, Lot 5, Block 2, Sunset PH 2

B. SPECIFICATIONS: No. Rooms 5 No. Stories 1 No. Structures 1

STRUCTURAL USE

CONSTRUCTION

OCCUPANCY

Residential/Single Family  
 Mixed Use  
 Commercial  
 Residential/Multi Family  
 Accessory Structure(s)

Box  
 Frame  
 Masonry  
 Mobile Home

Occupied  
 Vacant  
 Open

C. FINDINGS

01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2009 IRC AND 2011 NEC

Main structure?  Accessory structure?

02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base. Main structure?  Accessory structure?

03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated. Main structure?  Accessory structure?

04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated. Main structure?  Accessory structure?

05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used. Main structure?  Accessory structure?

06. The structure or any part thereof has inadequate means of egress as required by the city's building code. Main structure?  Accessory structure?


07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

light  
 ventilation  
 sanitation facilities

Main structure?  Accessory structure?



D. FLOOR PLAN (if necessary)



E. DETERMINATION

  X   1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.    Be vacated OR   X   remain unoccupied; and

B.    Be repaired OR   X   be demolished.

   2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.

*[Handwritten Signature]*  
Signature

*Charles S. Cox*  
Printed Name

5-14-15  
Date



# Dangerous Structures Survey Report

Fire Marshal

Case # 2111

A. PROPERTY ADDRESS: 905 W 16<sup>th</sup> Street, Lot 5, Block 2, Sunset PH 2

B. SPECIFICATIONS: No. Rooms \_\_\_\_\_ No. Stories 1 No. Structures 1

STRUCTURAL USE

CONSTRUCTION

OCCUPANCY

- Residential/Single Family  
 Mixed Use  
 Commercial  
 Residential/Multi Family  
 Accessory Structure

- Box  
 Frame  
 Masonry  
 Mobile Home

- Occupied  
 Vacant  
 Open

C. FINDINGS

01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare.  
I estimate that ~~100~~ % of the main structure is considered a loss.  
I estimate that     % of the accessory structure is considered a loss.
02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.  
Main Structure?  Accessory Structure?
03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.  
Main Structure?  Accessory Structure?
04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.  
Main Structure?  Accessory Structure?
05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.  
Main Structure?  Accessory Structure?
06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.  
Main Structure?  Accessory Structure?
07. The structure or a part thereof is in violation of the City's fire code.  
Main Structure?  Accessory Structure?

08. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.  
Main Structure?  Accessory Structure?

09. The building, structure, or a part thereof presents an attractive nuisance to children.  
Main Structure?  Accessory Structure?

**COMMENTS**

Inadequate wiring  
open wiring  
soft flexes  
Leaking Roof

**D. DETERMINATION**

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A.  Be vacated OR  remain unoccupied; and

B.  Be repaired OR  be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.



Signature

FRED TAYLOR / DSM

Printed Name/Title

5-13-15

Date