

**BUILDING AND STANDARDS COMMISSION
STAFF REPORT**

July 25, 2016



Case #2177 – 1608 Lucky Street



LEGAL DESCRIPTION: Henderson PH 2, Lot 13 & 14

STRUCTURE(S): single-family residence

PROPERTY OWNER(S): Mercer Ethel L Et.al.

**LIENHOLDER(S)/
MORTGAGEE(S):** none

ACTIVE UTILITIES: yes no **DISCONNECTED ON:** 6/20/1996

BRAZOS COUNTY APPRAISAL DISTRICT/TAX OFFICE INFORMATION:

PROPERTY ID: 28704

IMPROVEMENT VALUE: \$21,610

YEAR BUILT: 1945

SF OF LIVING AREA: 866

CURRENT OWNER SINCE: 6/6/1983

PROPERTY TAXES OWED: None

BACKGROUND:

- The Chief Building Official and Assistant Fire marshal noticed the structure in 2014, and again in early 2016. The home had been kept secured but conditions continue to worsen with parts of the structure failing to point of possible collapse.
- Notices that the property had an electrical hold on it from the Chief Building Official were mailed to the property owner on November 20, 2014.
- Notices that the property would be scheduled for consideration by the Building and Standards Commission were mailed to the property owner on May 23, 2016, and June 17, 2016.

ATTACHMENTS:

1. staff recommendation
2. pictures
3. dangerous structures survey reports

**BUILDING AND STANDARDS COMMISSION
STAFF RECOMMENDATION**



July 25, 2016

Case #: 2177

Building Address: 1608 Lucky Street

Record Owner(s): Mercer Ethel L Et.al.

The City's Chief Building Official has requested this Commission hearing to discuss the building on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):

- 1) The building, structure, or any part thereof is likely to partially or fully collapse.
- 2) The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3) One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4) The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5) The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6) The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7) The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8) The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9) The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

The City further recommends that the Commission find that:

- the building may not be feasibly repaired in compliance with City ordinances.**

The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:

- demolish the building and remove all debris within 30 days.**

The City recommends that the Commission orders that the City may:

- disconnect water and electric utilities to the building; and**
- secure the structure, demolish the building and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**

PICTURES:



Front of house – structure failing



Front corner, porch roof un-level, in danger of possible collapse



Side door, damaged outdated electrical service



Rear of house, damaged siding



Damaged front porch floor



Damaged front porch ceiling



Roof/overhang damage, damaged shingles, and wavy Box frame wall construction
Roof line



Evidence of termite damage



Rotten roof overhang



Dangerous Structures Survey Report

Chief Building Official

Case # 2177

A. PROPERTY ADDRESS: 1608 Lucky St., Henderson PH 2, Block 2, Lot 13 & 14

B. SPECIFICATIONS: No. Rooms 5+ No. Stories 1 No. Structures 1

STRUCTURAL USE

CONSTRUCTION

OCCUPANCY

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure(s)

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

C. FINDINGS

01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2009 IRC/2011 NEC
Main structure? Accessory structure?

02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base. Main structure? Accessory structure?

03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated. Main structure? Accessory structure?

04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated. Main structure? Accessory structure?

05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used. Main structure? Accessory structure?


06. The structure or any part thereof has inadequate means of egress as required by the city's building code. Main structure? Accessory structure?

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
- ventilation
- sanitation facilities

Main structure? Accessory structure?

D. FLOOR PLAN (if necessary)



E. DETERMINATION

1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:

A. Be vacated OR remain unoccupied; and

B. Be repaired OR be demolished.

2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.


Signature

GREGORY S. COX
Printed Name

6-10-16
Date



CITY OF BRYAN
The Good Life, Texas Style.

Dangerous Structures Survey Report

Fire Marshal

Case #2177

2016

A. PROPERTY ADDRESS: 1608 Lucky St., Henderson PH 2, Block 2, Lot 13 & 14

B. SPECIFICATIONS: No. Rooms _____ No. Stories 1 No. Structures 1

STRUCTURAL USE

CONSTRUCTION

OCCUPANCY

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

C. FINDINGS

- 01. The structure or a part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety, and welfare.
I estimate that 100 % of the main structure is considered a loss.
I estimate that — % of the accessory structure is considered a loss.
- 02. The structure or a part thereof has deteriorated to such an extent that it has become dangerous to the public health, safety, and welfare.
Main Structure? Accessory Structure?
- 03. The structure or a part thereof does not have adequate means of egress as required by the City's building code, and poses a danger in case of fire or panic.
Main Structure? Accessory Structure?
- 04. The structure or a part thereof lacks necessary fire-resistive construction, and the threat of a fire in the structure poses a risk to inhabitants, neighboring structures, and fire department personnel.
Main Structure? Accessory Structure?
- 05. Obsolete, damaged, or deteriorated electric wiring, gas connections, heating apparatus, or other mechanical infrastructure present a risk of fire.
Main Structure? Accessory Structure?
- 06. The proximity of the structure or a part thereof to other structures on this or neighboring properties constitutes a fire hazard for the other structures.
Main Structure? Accessory Structure?
- 07. The structure or a part thereof is in violation of the City's fire code.
Main Structure? Accessory Structure?

- 08. The building, structure, or a part thereof is being used by criminals, vagrants, or squatters for the purpose of suspected illegal activity.
Main Structure? Accessory Structure?
- 09. The building, structure, or a part thereof presents an attractive nuisance to children.
Main Structure? Accessory Structure?

COMMENTS WALLS out of plumb
Deflection in roof
Rotten siding & window jams
Front PORCH HAS SEVERE forward list

Exterior ONLY house appeared to dangerous
To Enter

D. DETERMINATION

- 1. It has been determined upon inspection and investigation that the structure is dangerous, unsafe, or a hazard to public health and must be secured and:
 - A. Be vacated OR remain unoccupied; and
 - B. Be repaired OR be demolished.
- 2. It has been determined upon inspection and investigation that the structure is not dangerous, unsafe, or a hazard to public health as defined by the City's Code of Ordinances.



Signature

FRED TAYLOR / DFM

Printed Name/Title

6-7-16

Date