

**BUILDING AND STANDARDS COMMISSION
STAFF REPORT**

March 28, 2016



Case # 2164 – 1304 Finfeather Road



LEGAL DESCRIPTION: Zeno Phillips League, TR.1: 61ft. by 367 ft., TR2: 8ft. By 172.3 ft

STRUCTURE(S): single-family residence
 accessory structure(s)

PROPERTY OWNER(S): Rosemary Vollmar

**LIENHOLDER(S)/
MORTGAGEE(S):** Zane Anderson - Judgment

ACTIVE UTILITIES: yes no **DISCONNECTED ON:** 10/22/2013

BRAZOS COUNTY APPRAISAL DISTRICT/TAX OFFICE INFORMATION:

PROPERTY ID: 51083
IMPROVEMENT VALUE: \$27,160
YEAR BUILT: 1952
SF OF LIVING AREA: 1,008
CURRENT OWNER SINCE: 11/9/2005
PROPERTY TAXES OWED: \$165.98 (2014)
\$86.42 (2015)

BACKGROUND:

- City permit records only show a plumbing permit and inspection for yard sewer repair in April 2001. No other permits or applications for permits have been applied for as of March 2, 2016 since at least 1998.
- The Bryan Police Department alerted the Chief Building Official and Assistant Fire Marshal that the property appeared to be in disrepair and appeared abandoned on July 9, 2014. A utility hold was placed on the structure and the owner was sent a notification letter on July 11, 2014 with a request to meet and inspect the structure with the owner. The owner never responded.
- In November 2015 and early January 2016, the Bryan Police Department found the structure unsecured after a citizen reported broken windows, and requested that it be considered for the Building and Standards Commission.
- Notices that the property would be scheduled for consideration by the Building and Standards Commission was mailed to the property owner on January 7, 2016, and February 11, 2016.
- As of March 2, 2016, the owner has not contacted the city about the structures.

ATTACHMENTS:

1. staff recommendation
2. pictures
3. dangerous structures survey reports

**BUILDING AND STANDARDS COMMISSION
STAFF RECOMMENDATION**



March 28, 2016

Case #: 2164

Building Address: 1304 Finfeather Road

Record Owner(s): Rosemary Vollmar

The City's Chief Building Official has requested this Commission hearing to discuss the building and two accessory structures on this property, and all legal notices of the hearing were provided to record owners, lienholders, and mortgagees. They were also notified that if they wanted to repair the building and/or accessory structures they needed to meet with City staff and come to the hearing with a detailed plan for repairs, including cost estimates. Based on the surveys, reports, photographs, and other evidence provided to the Commission, the City recommends that the Commission find the building unsafe based on the standards set forth in Bryan Code of Ordinances Section 14-224 subsection(s):

- 1) The building, structure, or any part thereof is likely to partially or fully collapse.
- 2) The structure or any part thereof was constructed or maintained in violation of any provision of the City's Building Code, or any other applicable ordinance or law of the city, county, state or federal government.
- 3) One or more walls or other vertical structural members list, lean, or buckle to such an extent that a plumb line passing through the center of gravity falls outside of the middle third or its base.
- 4) The foundation or the vertical or horizontal supporting members are twenty five percent (25%) or more damaged or deteriorated.
- 5) The non supporting coverings of walls, ceilings, roofs, or floors are fifty percent (50%) or more damaged or deteriorated.
- 6) The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used.
- 7) The structure or any part thereof has been damaged by fire, water, earthquake, wind, vandalism, or other cause to such an extent that it has become dangerous to the public health, safety and welfare.
- 8) The structure or any part thereof has inadequate means of egress as required by the City's Building Code.
- 9) The structure does not have adequate light ventilation, or sanitation facilities as required by the City's Building Codes and Plumbing Code.

The City further recommends that the Commission find that:

- the building is unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the building.**
- the accessory structures are unsecured and must be boarded up and/or fenced in such a manner to prevent unauthorized entry by a person, including a child, through missing or unlocked doors or windows or through other openings into the structures.**

- the building may feasibly be repaired so that it is no longer in violation of City ordinances; however the house appears to have been unoccupied and apparently not been maintained for at least 2 years, been left unsecured, and repairs and continued maintenance are therefore not likely; no plans, estimates, and timeline for repairs have not been submitted.**

The City recommends that the Commission issue an order to the owner, lienholder, or mortgagee to:

- secure the building and accessory structures from unauthorized entry within 30 days.**
- demolish the building and accessory structures and remove the debris within 30 days.**

The City recommends that the Commission orders that the City may:

- disconnect water and electric utilities to the building and accessory structures; and**
- secure the building and accessory structures, demolish the building and accessory structures and remove the debris in accordance with Chapter 14 of the City of Bryan's Code of Ordinances if the owner, lienholder, or mortgagee fails to comply with the Commission's order.**

PICTURES:



Front of house from Finfeather Rd.



Broken unsecured window




Front of house, overgrown yard



Cracks in sheetrock at ceilings and walls



Damaged / loose light fixtures



Missing electrical outlet covers



Water damage at wall below furnace



Electrical panel, cracks in sheetrock wall



Trash and debris, food left behind



Evidence of rat/mice infestation



The attic area has evidence of a previous fire
No attic insulation



Openings to exterior, open electrical junction boxes



Front left side of home



Outdated meter base – needs new service



Rotten rear deck and ramp, damaged siding



Rear corner of house



Detached garage, damaged siding, door with broken glass, unsecured openings



Interior of detached garage



Rafters of detached garage, not adequate for span



Detached accessory storage structure



Rotten framing in detached accessory storage structure, damaged electrical panel



The detached storage structure appears to be in side setback and is too close to neighboring commercial business (not enough fire separation).



Dangerous Structures Survey Report

Chief Building Official

Case # 2164

A. PROPERTY ADDRESS: 1304 Finfeather Road, Zeno Phillips, Block 16, Lot 3 (TR-94)

B. SPECIFICATIONS: No. Rooms 5 No. Stories 1 No. Structures 3

STRUCTURAL USE

CONSTRUCTION

OCCUPANCY

- Residential/Single Family
- Mixed Use
- Commercial
- Residential/Multi Family
- Accessory Structure(s)

- Box
- Frame
- Masonry
- Mobile Home

- Occupied
- Vacant
- Open

C. FINDINGS

01. The structure or a part thereof was constructed or maintained in violation of a provision of the City's building code, other applicable ordinance, state law, or federal law. Specifically, the following:

2009 IRC – 2011 NEC
 Main structure? Accessory structure?

02. Any wall or other vertical structural members list, lean, or buckle to an extent that a plumbline passing through the center of gravity falls outside of the middle third of its base. Main structure? Accessory structure?

03. The foundation or the vertical or horizontal supporting members are materially damaged or deteriorated. Main structure? Accessory structure?

04. The non-supporting coverings of walls, ceilings, roofs, or floors are materially damaged or deteriorated. Main structure? Accessory structure?

05. The structure has improperly distributed loads upon the structural members, or they have insufficient strength to be reasonably safe for the purpose used. Main structure? Accessory structure?

06. The structure or any part thereof has inadequate means of egress as required by the city's building code. Main structure? Accessory structure?

07. The structure is unsanitary, unfit for human habitation, or likely to cause sickness due to damage, deterioration, or inadequate design/construction. Specifically the structure does not meet the city's requirements for:

- light
 - ventilation
 - sanitation facilities
- Main structure? Accessory structure?