

Brooke T. Paup, *Chairwoman*
Bobby Janecka, *Commissioner*
Catarina R. Gonzales, *Commissioner*
Kelly Keel, *Executive Director*



PWS_0210001_CO_20250205_Plan Ltr

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

February 5, 2025

Kent M. Laza, P.E.
KTL Engineering, LLC
4913 Farm-to-Market 166
Caldwell, TX 77836

Re: City of Bryan - Public Water System ID No. 0210001
Proposed SOS Ministries Campus Waterline Extension - less than 10%
Engineer Contact Telephone: (979) 220-1957
Plan Review Log No. P-12032024-027
Brazos County, Texas

CN600373310 RN101217917

Dear Mr. Laza:

On December 3, 2024, the Texas Commission on Environmental Quality (TCEQ) received notification dated September 12, 2024 of the proposed changes to the above referenced public water system. Based on our review of the information submitted, it appears that the proposed project consisting of the construction of distribution lines and one service connection constitutes less than ten percent of the 27,272 existing service connections of the above referenced public water system; therefore, it **does not require the submission of engineering plans and specifications** for commission review and approval under the provisions of Title 30 Texas Administrative Code (TAC) §290.39(j)(1)(D).

The design and construction of the proposed waterline must comply with the provisions of 30 TAC Chapter 290 of the TCEQ's Rules and Regulations for Public Water Systems.

The project consists of:

- Approximately 224 linear feet of 8-inch American Water Works Association Standard C900, polyvinyl chloride, dimension ratio 14 waterline; and
- Associated valves, fittings, and appurtenances.

The City of Bryan public water supply system provides water treatment.

The project is located at Loop Street and Rosemay Drive in Brazos County, Texas. 30 TAC Section 290.39(j) requires that you notify the TCEQ Region 9 Office by email at R9PWS@TCEQ.Texas.gov at commencement and completion of construction as required in the rule.

Please refer to the Plan Review Team's Log No. **P-12032024-027** in all correspondence for this project.

Kent M. Laza, P.E.
Page 2
February 5, 2025

Please complete a copy of the most current Public Water System Plan Review Submittal form for any future submittals to TCEQ. Every blank on the form must be completed to minimize any delays in the review of your project. The document is available on TCEQ's website at the address shown below. You can also download the most current plan submittal checklists and forms from the same address.

<https://www.tceq.texas.gov/drinkingwater/udpubs.html>

For future reference, you can review part of the Plan Review Team's database to see if we have received your project. This is available on TCEQ's website at the following address:

<https://www.tceq.texas.gov/drinkingwater/planrev.html/#status>

You can download the latest revision of 30 TAC Chapter 290 - Rules and Regulations for Public Water Systems from this site.


If you have any questions concerning this letter or need further assistance, please contact David Smith at 512-239-4703 or by email David.smith@tceq.texas.gov or by correspondence at the following address:

Plan Review Team, MC-159
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Sincerely,



David T. Smith, P.E.
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality



For Craig A. Stowell, P.E., Team Leader
Plan Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

CAS/DTS/vj/av

cc: City of Bryan, Attn: Honorable Mayor, Bobby Gutierrez, P.O. Box 1000, Bryan, Texas
77805-1000